



RAdata, Inc.
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: Gary Tattersall
Ocean Township School District
163 Monmouth Road
Oakhurst, NJ 077550000

Laboratory Results

Sample Number **Sample Location** **Collected By**
0617-6306 901 Bendermere Avenue - Ocean Twp Kevin, Schmitz

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0617-6306	6/10/2017 7:46:00 AM New Boiler Room Water Main Source	6/19/2017 9:07:00 AM	Lead (Source)	121 ug/l*	5 ug/L	Std Method 3113B
0617-6306-10	6/10/2017 7:49:00 AM Rm 114 Wana SB 114	6/16/2017 9:07:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6306-11	6/10/2017 7:51:00 AM K Wing Boy Side Wana WC B	6/16/2017 9:07:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6306-12	6/10/2017 7:52:00 AM K Wing Girl Side Wana WC G	6/16/2017 9:07:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6306-13	6/10/2017 7:54:00 AM Rm 105 Wana SB 105	6/16/2017 9:07:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6306-14	6/10/2017 7:57:00 AM Rm 104 Wana SB 104	6/16/2017 9:07:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6306-15	6/10/2017 7:59:00 AM Rm 103 Wana SB 103	6/16/2017 9:07:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6306-16	6/10/2017 8:02:00 AM Rm 102 Wana SB 102	6/16/2017 9:07:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6306-17	6/10/2017 8:05:00 AM Rm 110 Wana SB 110	6/16/2017 9:07:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6306-18	6/10/2017 8:07:00 AM Rm 111 Wana SB 111	6/16/2017 9:07:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6306-19	6/10/2017 8:10:00 AM Rm 112 Wana SB 112	6/16/2017 9:07:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6306-2	6/10/2017 8:13:00 AM Rm 113 Wana SB 113	6/16/2017 9:07:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6306-20	6/10/2017 8:16:00 AM Rm 122 Wana SB 122	6/19/2017 9:07:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6306-21	6/10/2017 8:18:00 AM Cafeteria Office Wana KC Café	6/19/2017 9:07:00 AM	Lead (1st Draw)	12.8 ug/l	15 ug/L	Std Method 3113B
0617-6306-22	6/10/2017 8:21:00 AM Outside Art Room Wana WC Art	6/19/2017 9:07:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, July 11, 2017

NJDEP Laboratory Certification # 14006

Page 1 of 3



RAdata, Inc.
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: Gary Tattersall
 Ocean Township School District
 163 Monmouth Road
 Oakhurst, NJ 077550000

Laboratory Results

Sample Number **Sample Location** **Collected By**
 0617-6306 901 Bendermere Avenue - Ocean Twp Kevin, Schmitz

Sample No.	Collected	Analyzed	Parameter	Result	MCL [#]	Method
0617-6306-23	6/10/2017 8:23:00 AM Outside Rm 23 Wana WC - 23	6/19/2017 9:07:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6306-24	6/10/2017 8:27:00 AM Outside Rm 8 Wana WC - 8	6/19/2017 9:07:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6306-25	6/10/2017 8:29:00 AM 1st Floor Teacher Lounge - Wana TL	6/19/2017 9:07:00 AM	Lead (1st Draw)	3.25 ug/l	15 ug/L	Std Method 3113B
0617-6306-3	6/10/2017 8:33:00 AM Nurses Office Wana NS Nurse	6/19/2017 9:07:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6306-4	6/10/2017 8:36:00 AM Outside Room 11 Wana WC - 11	6/19/2017 9:07:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6306-5	6/10/2017 8:39:00 AM K-2 Wana SB - K2	6/19/2017 9:07:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6306-6	6/10/2017 8:41:00 AM K-1 Wana SB - K1	6/19/2017 9:07:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6306-7	6/10/2017 8:44:00 AM K Wing Boys Side Wana WC - 97B	6/19/2017 9:07:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6306-8	6/10/2017 8:46:00 AM K Wing Girls Side Wana WC - 97G	6/19/2017 9:07:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6306-9	6/10/2017 8:54:00 AM New Boiler Room Source 2nd	6/19/2017 9:07:00 AM	Lead (Source)	136 ug/l*	5 ug/L	Std Method 3113B

[#] MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, July 11, 2017

NJDEP Laboratory Certification # 14006

Page 2 of 3



RAdata, Inc.
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: Gary Tattersall
Ocean Township School District
163 Monmouth Road
Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By
0617-6306	901 Bendermere Avenue - Ocean Twp	Kevin, Schmitz

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
------------	-----------	----------	-----------	--------	-------	--------

**Some or All of the parameters tested on this report
DID NOT PASS NJ Drinking Water Standards.**

This report represents results associated to the point of collection location in the structure only. It is recommended that other locations within the structure where water can be consumed, be tested to verify compliance to state and federal drinking water regulations.

NOTE : 0617-6306-9 (New Boiler Room Source 2nd) = Non-Drinking Water Spigot - Not a Source

Reviewed and Approved by:

Timothy P. Kroder, Laboratory Manager

MCL - Maximum Contaminant Level
ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, July 11, 2017

NJDEP Laboratory Certification # 14006

Page 3 of 3



RAdata, Inc.
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: Gary Tattersall
 Ocean Township School District
 163 Monmouth Road
 Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By					
0617-6307	555 Dow Avenue - Ocean Twp	Kevin, Schmitz					
Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method	
0617-6307	6/10/2017 9:32:00 AM Basement Utility Sink Source	6/23/2017 8:24:00 AM	Lead (Source)	220 ug/l*	5 ug/L	Std Method 3113B	
0617-6307-10	6/10/2017 9:36:00 AM Nurses Office	6/23/2017 8:24:00 AM	Lead (1st Draw)	2.27 ug/l	15 ug/L	Std Method 3113B	
0617-6307-11	6/10/2017 9:38:00 AM Outside Room 101L	6/23/2017 8:24:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6307-12	6/10/2017 9:39:00 AM Outside Room 101R	6/23/2017 8:24:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6307-13	6/10/2017 9:41:00 AM Outside First Floor Girls Room	6/23/2017 8:24:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6307-14	6/10/2017 9:42:00 AM Outside First Floor Boys Room	6/23/2017 8:24:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6307-15	6/10/2017 9:45:00 AM Outside Rm 115 Left	6/23/2017 8:24:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6307-16	6/10/2017 9:47:00 AM Outside Rm 115 Right	6/23/2017 8:24:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6307-17	6/10/2017 9:50:00 AM Outside Rm 215 Left	6/23/2017 8:24:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6307-18	6/10/2017 9:52:00 AM Outside Rm 215 Right	6/23/2017 8:24:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6307-19	6/10/2017 9:55:00 AM Outside 2nd Floor Girls Room	6/23/2017 8:24:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6307-2	6/10/2017 9:58:00 AM Outside 2nd Floor Boys Room	6/23/2017 8:24:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6307-20	6/10/2017 10:01:00 AM Outside 2nd Floor Rm 201 L	6/23/2017 8:24:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6307-21	6/10/2017 10:03:00 AM Outside 2nd Floor Rm 201 R	6/23/2017 8:24:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6307-22	6/10/2017 10:06:00 AM Hall Near Custodian Right	6/23/2017 8:24:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, July 11, 2017

NJDEP Laboratory Certification # 14006

Page 1 of 3



RAdata, Inc.
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: Gary Tattersall
Ocean Township School District
163 Monmouth Road
Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By					
0617-6307	555 Dow Avenue - Ocean Twp	Kevin, Schmitz					
Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method	
0617-6307-23	6/10/2017 10:10:00 AM Hall Near Custodian Center	6/23/2017 8:24:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6307-24	6/10/2017 10:13:00 AM Hall Near Custodian Left	6/23/2017 8:24:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6307-25	6/10/2017 10:17:00 AM Inside Room 99	6/23/2017 8:24:00 AM	Lead (1st Draw)	2.54 ug/l	15 ug/L	Std Method 3113B	
0617-6307-26	6/10/2017 10:22:00 AM Outside Room 99	6/23/2017 8:24:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6307-3	6/10/2017 10:24:00 AM Outside Room 100	6/27/2017 8:34:00 AM	Lead (1st Draw)	2.15 ug/l	15 ug/L	Std Method 3113B	
0617-6307-4	6/10/2017 10:28:00 AM Inside Room 100	6/27/2017 8:34:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6307-5	6/10/2017 10:30:00 AM K1 Dow-DW-K1	6/27/2017 8:34:00 AM	Lead (1st Draw)	3.94 ug/l	15 ug/L	Std Method 3113B	
0617-6307-6	6/10/2017 10:33:00 AM K2 Dow-DW-K2	6/27/2017 8:34:00 AM	Lead (1st Draw)	3.97 ug/l	15 ug/L	Std Method 3113B	
0617-6307-7	6/10/2017 10:36:00 AM Café Dow-WC Café	6/27/2017 8:34:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6307-8	6/10/2017 10:39:00 AM Kitchen Dow KK Kitchen	6/27/2017 8:34:00 AM	Lead (1st Draw)	7.79 ug/l	15 ug/L	Std Method 3113B	
0617-6307-9	6/10/2017 10:48:00 AM Basement Utility Sink Source 2nd	6/27/2017 8:34:00 AM	Lead	77.8 ug/l*	5 ug/l	Std Method 3113B	

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, July 11, 2017

NJDEP Laboratory Certification # 14006

Page 2 of 3



RAdata, Inc.
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: Gary Tattersall
Ocean Township School District
163 Monmouth Road
Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By
0617-6307	555 Dow Avenue - Ocean Twp	Kevin, Schmitz

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
------------	-----------	----------	-----------	--------	-------	--------

**Some or All of the parameters tested on this report
DID NOT PASS NJ Drinking Water Standards.**

This report represents results associated to the point of collection location in the structure only. It is recommended that other locations within the structure where water can be consumed, be tested to verify compliance to state and federal drinking water regulations.

NOTE : Field Blank = 4.31 ug/L

Reviewed and Approved by:

Timothy P. Kroder, Laboratory Manager

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, July 11, 2017

NJDEP Laboratory Certification # 14006

Page 3 of 3



RAdata, Inc.
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: Gary Tattersall
 Ocean Township School District
 163 Monmouth Road
 Oakhurst, NJ 077550000

Laboratory Results

Sample Number **Sample Location** **Collected By**
 0617-6308 550 West Park Avenue - Ocean Twp Kevin, Schmitz

Sample No.	Collected	Analyzed	Parameter	Result	MCL [#]	Method
0617-6308	6/10/2017 11:37:00 AM Boiler Room Spigot Source	6/27/2017 8:34:00 AM	Lead (Source)	120 ug/l*	5 ug/L	Std Method 3113B
0617-6308-10	6/10/2017 11:43:00 AM A Hall Boys/Girls A Left	6/27/2017 8:34:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-11	6/10/2017 11:44:00 AM A Hall Boys/Girls B Center	6/27/2017 8:34:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-12	6/10/2017 11:46:00 AM A Hall Boys/Girls C Right	6/27/2017 8:34:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-13	6/10/2017 11:50:00 AM B Hall Boys/Girls Near Gym A Left	6/27/2017 8:34:00 AM	Lead (1st Draw)	5.27 ug/l	15 ug/L	Std Method 3113B
0617-6308-14	6/10/2017 11:52:00 AM B Hall Boys/Girls Near Gym B Center	6/27/2017 8:34:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-15	6/10/2017 11:54:00 AM B Hall Boys/Girls Near Gym C Right	6/27/2017 8:34:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-16	6/10/2017 11:57:00 AM B Hall Center B/G A Left	6/27/2017 8:34:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-17	6/10/2017 12:00:00 PM B Hall Center B/G B Center	6/27/2017 8:34:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-18	6/10/2017 12:02:00 PM B Hall Center B/G C Right	6/27/2017 8:34:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-19	6/10/2017 12:06:00 PM B Halls Mens/Womens A Left	6/27/2017 8:34:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-2	6/10/2017 12:08:00 PM B Halls Mens/Womens B Center	6/27/2017 8:34:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-20	6/10/2017 12:11:00 PM B Halls Mens/Womens C Right	6/27/2017 8:34:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-21	6/10/2017 12:16:00 PM B Hall 2nd Floor B/G A Left	6/27/2017 8:34:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-22	6/10/2017 12:18:00 PM B Hall 2nd Floor B/G B Center	6/27/2017 8:34:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, July 11, 2017

NJDEP Laboratory Certification # 14006

Page 1 of 4



RAdata, Inc.
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: Gary Tattersall
 Ocean Township School District
 163 Monmouth Road
 Oakhurst, NJ 077650000

Laboratory Results

Sample Number **Sample Location** **Collected By**
 0617-6308 550 West Park Avenue - Ocean Twp Kevin, Schmitz

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0617-6308-23	6/10/2017 12:21:00 PM B Hall 2nd Floor B/G C Right	6/29/2017 8:33:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-24	6/10/2017 12:25:00 PM E Wing Between B/G	6/29/2017 8:33:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-25	6/10/2017 12:29:00 PM C Hall Near Library A Left	6/29/2017 8:33:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-26	6/10/2017 12:31:00 PM C Hall Near Library B Center	6/29/2017 8:33:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-27	6/10/2017 12:34:00 AM C Hall Near Library B Right	6/29/2017 8:33:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-28	6/10/2017 12:39:00 AM Home EC Sink 1	6/29/2017 8:33:00 AM	Lead (1st Draw)	5.04 ug/l	15 ug/L	Std Method 3113B
0617-6308-29	6/10/2017 12:42:00 AM Home EC Sink 2	6/29/2017 8:33:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-3	6/10/2017 12:44:00 AM Home EC Sink 3	6/29/2017 8:33:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-30	6/10/2017 12:46:00 AM Home EC Sink 4	6/29/2017 8:33:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-31	6/10/2017 12:49:00 AM Home EC Sink 5	6/29/2017 8:33:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-32	6/10/2017 12:52:00 AM Home EC Sink 6	6/29/2017 8:33:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-33	6/10/2017 12:56:00 AM D Hall Center B/G A Left	6/29/2017 8:33:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-34	6/10/2017 12:58:00 AM D Hall Center B/G B Center	6/29/2017 8:33:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-35	6/10/2017 1:01:00 PM D Hall Center B/G C Right	6/29/2017 8:33:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-36	6/10/2017 1:06:00 PM D Hall Center 2nd Floor B/G A Left	6/29/2017 8:33:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, July 11, 2017

NJDEP Laboratory Certification # 14006

Page 2 of 4



RAdata, Inc.
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: Gary Tattersall
Ocean Township School District
163 Monmouth Road
Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By
0617-6308	550 West Park Avenue - Ocean Twp	Kevin, Schmitz

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0617-6308-37	6/10/2017 1:09:00 PM D Hall Center 2nd Floor B/G B Center	6/29/2017 8:33:00 AM	Lead (1st Draw)	4.54 ug/l	15 ug/L	Std Method 3113B
0617-6308-38	6/10/2017 1:11:00 PM D Hall Center 2nd Floor B/G C Right	6/29/2017 8:33:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-39	6/10/2017 1:17:00 PM Kitchen Left of Kettle	6/29/2017 8:33:00 AM	Lead (1st Draw)	54.6 ug/l*	15 ug/L	Std Method 3113B
0617-6308-4	6/10/2017 1:20:00 PM Kitchen Across From Kettle	6/29/2017 8:33:00 AM	Lead (1st Draw)	4.72 ug/l	15 ug/L	Std Method 3113B
0617-6308-40	6/10/2017 1:23:00 PM Kitchen Backs Up to Outlet With Spray	6/29/2017 8:33:00 AM	Lead (1st Draw)	3.74 ug/l	15 ug/L	Std Method 3113B
0617-6308-41	6/10/2017 1:26:00 PM Kitchen Outlet With Spray Near Walk In	6/29/2017 8:33:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-5	6/10/2017 1:30:00 PM Kitchen Left of Spray Near Walk In	6/29/2017 8:33:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-6	6/10/2017 1:36:00 PM Girls Locker Room	6/29/2017 8:33:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-7	6/10/2017 1:41:00 PM Boys Locker Room	6/29/2017 8:33:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-8	6/10/2017 1:48:00 PM Trainers Room Ice Machine	6/29/2017 8:33:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6308-9	6/10/2017 1:53:00 PM Boiler Room Source 2 Spigot	6/29/2017 8:33:00 AM	Lead	76.2 ug/l*	5 ug/l	Std Method 3113B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, July 11, 2017

NJDEP Laboratory Certification # 14006

Page 3 of 4



RAdata, Inc.
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: Gary Tattersall
Ocean Township School District
163 Monmouth Road
Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By
0617-6308	550 West Park Avenue - Ocean Twp	Kevin, Schmitz

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
------------	-----------	----------	-----------	--------	-------	--------

**Some or All of the parameters tested on this report DID NOT
PASS NJ Drinking Water Standards.**

This report represents results associated to the point of collection location in the structure only. It is recommended that other locations within the structure where water can be consumed, be tested to verify compliance to state and federal drinking water regulations.

NOTE : 0617-6308-9 (Boiler Room Source 2 Spigot) = Non-Drinking Water Spigot - Not a Source

Reviewed and Approved by:

Timothy P. Kroder, Laboratory Manager

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, July 11, 2017

NJDEP Laboratory Certification # 14006

Page 4 of 4



RAdata, Inc.
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: Gary Tattersall
 Ocean Township School District
 163 Monmouth Road
 Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By					
0617-6309	733 Bowne Road - Ocean Twp	Richard, Hand					
Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method	
0617-6309	6/10/2017 7:46:00 AM Room 721 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-10	6/10/2017 7:50:00 AM Fountain Between 721 & 722	7/10/2017 8:48:00 AM	Lead (1st Draw)	2.05 ug/l	15 ug/L	Std Method 3113B	
0617-6309-11	6/10/2017 7:52:00 AM Rm 722 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-12	6/10/2017 7:58:00 AM Nurse Office Main Sink	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-13	6/10/2017 8:00:00 AM Fountain By Nurse Office	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-14	6/10/2017 8:03:00 AM Teachers Lounge Sink	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-15	6/10/2017 8:05:00 AM Fountain By Teachers Lounge	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-16	6/10/2017 8:10:00 AM Fountain Wing 1 Across From Custodian	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-17	6/10/2017 8:12:00 AM Rm 104 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	3.93 ug/l	15 ug/L	Std Method 3113B	
0617-6309-18	6/10/2017 8:16:00 AM Rm 105 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-19	6/10/2017 8:19:00 AM Rm 106 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-2	6/10/2017 8:21:00 AM Rm 107 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-20	6/10/2017 8:24:00 AM Rm 108 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-21	6/10/2017 8:26:00 AM Rm 101 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	4.80 ug/l	15 ug/L	Std Method 3113B	
0617-6309-22	6/10/2017 8:29:00 AM Rm 102 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	2.77 ug/l	15 ug/L	Std Method 3113B	

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, July 11, 2017

NJDEP Laboratory Certification # 14006

Page 1 of 5



RAdata, Inc.
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: Gary Tattersall
 Ocean Township School District
 163 Monmouth Road
 Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By					
0617-6309	733 Bowne Road - Ocean Twp	Richard, Hand					
Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method	
0617-6309-23	6/10/2017 8:32:00 AM Rm 100 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-24	6/10/2017 8:35:00 AM Rm 103 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-25	6/10/2017 8:39:00 AM Fountain Wing 2 By Custodian Closet	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-26	6/10/2017 8:43:00 AM Rm 204 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-27	6/10/2017 8:46:00 AM Rm 203 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-28	6/10/2017 8:49:00 AM Rm 202 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	2.24 ug/l	15 ug/L	Std Method 3113B	
0617-6309-29	6/10/2017 8:51:00 AM Rm 201 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-3	6/10/2017 8:54:00 AM Rm 208 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-30	6/10/2017 8:56:00 AM Rm 207 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-31	6/10/2017 8:58:00 AM Rm 206 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-32	6/10/2017 9:01:00 AM Rm 200 Left Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	10.7 ug/l	15 ug/L	Std Method 3113B	
0617-6309-33	6/10/2017 9:03:00 AM Rm 200 Right Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	2.97 ug/l	15 ug/L	Std Method 3113B	
0617-6309-34	6/10/2017 9:06:00 AM Rm 205 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-35	6/10/2017 9:11:00 AM Rm 606 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-36	6/10/2017 9:13:00 AM Rm 608 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	48.8 ug/l*	15 ug/L	Std Method 3113B	

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, July 11, 2017

NJDEP Laboratory Certification # 14006

Page 2 of 5



RAdata, Inc.
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: Gary Tattersall
 Ocean Township School District
 163 Monmouth Road
 Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By
0617-6309	733 Bowne Road - Ocean Twp	Richard, Hand

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0617-6309-37	6/10/2017 9:16:00 AM Fountain Wing 3 By Custodian Closet	7/10/2017 8:48:00 AM	Lead (1st Draw)	2.80 ug/l	15 ug/L	Std Method 3113B
0617-6309-38	6/10/2017 9:18:00 AM Rm 304 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6309-39	6/10/2017 9:20:00 AM Rm 303 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6309-4	6/10/2017 9:22:00 AM Rm 302 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6309-40	6/10/2017 9:24:00 AM Rm 301 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6309-41	6/10/2017 9:27:00 AM Rm 308 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6309-42	6/10/2017 9:30:00 AM Rm 307 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6309-43	6/10/2017 9:32:00 AM Rm 306 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6309-44	6/10/2017 9:36:00 AM Rm 305 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6309-45	6/10/2017 9:39:00 AM Rm 300 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	2.99 ug/l	15 ug/L	Std Method 3113B
0617-6309-46	6/10/2017 9:50:00 AM Rm 401 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6309-47	6/10/2017 9:52:00 AM Fountain Across 402 Left	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6309-48	6/10/2017 9:53:00 AM Fountain Across 402 Right	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6309-49	6/10/2017 9:55:00 AM Rm 402 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6309-5	6/10/2017 9:57:00 AM Rm 403 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, July 11, 2017

NJDEP Laboratory Certification # 14006

Page 3 of 5



RAdata, Inc.
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: Gary Tattersall
 Ocean Township School District
 163 Monmouth Road
 Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By					
0617-6309	733 Bowne Road - Ocean Twp	Richard, Hand					
Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method	
0617-6309-50	6/10/2017 10:00:00 AM Rm 412 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-51	6/10/2017 10:03:00 AM Rm 404 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-52	6/10/2017 10:05:00 AM Rm 405 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-53	6/10/2017 10:07:00 AM Rm 410 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-54	6/10/2017 10:09:00 AM Rm 411 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-55	6/10/2017 10:12:00 AM Rm 406 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-6	6/10/2017 10:16:00 AM Rm 407 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-7	6/10/2017 10:19:00 AM Rm 408 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-8	6/10/2017 10:22:00 AM Rm 409 Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6309-9	6/10/2017 10:30:00 AM Rm 721 Source Bubbler	7/10/2017 8:48:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, July 11, 2017

NJDEP Laboratory Certification # 14006

Page 4 of 5



RAdata, Inc.
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: Gary Tattersall
Ocean Township School District
163 Monmouth Road
Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By
0617-6309	733 Bowne Road - Ocean Twp	Richard, Hand

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
------------	-----------	----------	-----------	--------	-------	--------

**Some or All of the parameters tested on this report DID NOT
PASS NJ Drinking Water Standards.**

*This report represents results associated to the point of collection location in the structure only. It is
recommended that other locations within the structure where water can be consumed, be tested to verify
compliance to state and federal drinking water regulations.*

Reviewed and Approved by:

Timothy P. Kroder, Laboratory Manager

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, July 11, 2017

NJDEP Laboratory Certification # 14006

Page 5 of 5



RAdata, Inc.
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: Gary Tattersall
 Ocean Township School District
 163 Monmouth Road
 Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By					
0617-6310	1200 West Park Avenue - Ocean Twp	Richard, Hand					
Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method	
0617-6310	6/10/2017 11:30:00 AM Fountain FF By Rm 5143	7/3/2017 8:32:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6310-10	6/10/2017 11:33:00 AM Fountain FF By Rm 5112	7/3/2017 8:32:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6310-11	6/10/2017 11:34:00 AM Fountain FF By Rm 5133	7/3/2017 8:32:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6310-12	6/10/2017 11:37:00 AM Fountain FF Near Rm 5104	7/3/2017 8:32:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6310-13	6/10/2017 11:39:00 AM Fountain FF Across Rm 5104	7/3/2017 8:32:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6310-14	6/10/2017 11:44:00 AM Office 5121 Kitchen Sink	7/3/2017 8:32:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6310-15	6/10/2017 11:49:00 AM Fountain Across From Rm 5205	7/3/2017 8:32:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6310-16	6/10/2017 11:53:00 AM Fountain Near Rm 5227	7/3/2017 8:32:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6310-17	6/10/2017 11:58:00 AM 5214 Teachers Lounge Sink	7/6/2017 8:36:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6310-18	6/10/2017 12:06:00 AM Nurses Office Main Sink	7/6/2017 8:36:00 AM	Lead (1st Draw)	3.45 ug/l	15 ug/L	Std Method 3113B	
0617-6310-19	6/10/2017 12:11:00 AM Fountain Gym Hall Across Rm 310	7/6/2017 8:36:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6310-2	6/10/2017 12:14:00 AM Fountain Outside Boys Locker Rm	7/6/2017 8:36:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6310-20	6/10/2017 12:17:00 AM Fountain Outside Girls Locker Room	7/6/2017 8:36:00 AM	Lead (1st Draw)	3.41 ug/l	15 ug/L	Std Method 3113B	
0617-6310-21	6/10/2017 12:25:00 AM Fountain Gym Hall Girls By 208	7/6/2017 8:36:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B	
0617-6310-22	6/10/2017 12:30:00 AM Kitchen Kettle	7/6/2017 8:36:00 AM	Lead (1st Draw)	6.33 ug/l	15 ug/L	Std Method 3113B	

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, July 11, 2017

NJDEP Laboratory Certification # 14006

Page 1 of 4



RAdata, Inc.
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: Gary Tattersall
 Ocean Township School District
 163 Monmouth Road
 Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By						
0617-6310	1200 West Park Avenue - Ocean Twp	Richard, Hand						
Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method		
0617-6310-23	6/10/2017 12:37:00 AM Lunch Rm Near Main Entrance Sink	7/6/2017 8:36:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B		
0617-6310-24	6/10/2017 12:40:00 AM Left Fountain Across From Band Room	7/6/2017 8:36:00 AM	Lead (1st Draw)	2.71 ug/l	15 ug/L	Std Method 3113B		
0617-6310-25	6/10/2017 12:41:00 AM Right Fountain Across From Band Room	7/6/2017 8:36:00 AM	Lead (1st Draw)	8.42 ug/l	15 ug/L	Std Method 3113B		
0617-6310-26	6/10/2017 12:46:00 AM Fountain Main Office Hall	7/6/2017 8:36:00 AM	Lead (1st Draw)	5.04 ug/l	15 ug/L	Std Method 3113B		
0617-6310-27	6/10/2017 12:49:00 AM Main Office Kitchen Sink	7/6/2017 8:36:00 AM	Lead (1st Draw)	6.31 ug/l	15 ug/L	Std Method 3113B		
0617-6310-28	6/10/2017 12:52:00 AM Fountain Across From Music	7/6/2017 8:36:00 AM	Lead (1st Draw)	5.90 ug/l	15 ug/L	Std Method 3113B		
0617-6310-29	6/10/2017 12:57:00 AM Fountain 1st Floor 6th Grade Hall	7/6/2017 8:36:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B		
0617-6310-3	6/10/2017 12:59:00 AM Rm 606 Sink	7/6/2017 8:36:00 AM	Lead (1st Draw)	13.1 ug/l	15 ug/L	Std Method 3113B		
0617-6310-30	6/10/2017 1:01:00 PM Rm 607 Sink	7/6/2017 8:36:00 AM	Lead (1st Draw)	53.6 ug/l*	15 ug/L	Std Method 3113B		
0617-6310-31	6/10/2017 1:04:00 PM Fountain FF 7th Grade Hall Left	7/6/2017 8:36:00 AM	Lead (1st Draw)	3.48 ug/l	15 ug/L	Std Method 3113B		
0617-6310-32	6/10/2017 1:05:00 PM Fountain FF 7th Grade Hall Right	7/6/2017 8:36:00 AM	Lead (1st Draw)	7.21 ug/l	15 ug/L	Std Method 3113B		
0617-6310-33	6/10/2017 1:09:00 PM Rm 706 Sink	7/6/2017 8:36:00 AM	Lead (1st Draw)	2.48 ug/l	15 ug/L	Std Method 3113B		
0617-6310-34	6/10/2017 1:13:00 PM Fountain FF 8th Grade Hall (Point)	7/6/2017 8:36:00 AM	Lead (1st Draw)	4.45 ug/l	15 ug/L	Std Method 3113B		
0617-6310-35	6/10/2017 1:16:00 PM Rm 806 Sink	7/6/2017 8:36:00 AM	Lead (1st Draw)	4.92 ug/l	15 ug/L	Std Method 3113B		
0617-6310-36	6/10/2017 1:19:00 PM Rm 601 Imc Sink	7/6/2017 8:36:00 AM	Lead (1st Draw)	8.75 ug/l	15 ug/L	Std Method 3113B		

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, July 11, 2017

NJDEP Laboratory Certification # 14006

Page 2 of 4



RAdata, Inc.
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: Gary Tattersall
Ocean Township School District
163 Monmouth Road
Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By
0617-6310	1200 West Park Avenue - Ocean Twp	Richard, Hand

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0617-6310-37	6/10/2017 1:32:00 PM Main Office Fountain	7/6/2017 8:36:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6310-38	6/10/2017 1:38:00 PM Fountain Across 651	7/6/2017 8:36:00 AM	Lead (1st Draw)	2.60 ug/l	15 ug/L	Std Method 3113B
0617-6310-39	6/10/2017 1:40:00 PM Fountain Across 656	7/6/2017 8:36:00 AM	Lead (1st Draw)	5.07 ug/l	15 ug/L	Std Method 3113B
0617-6310-4	6/10/2017 1:42:00 PM Teachers Rm 661 Sink	7/6/2017 8:36:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0617-6310-40	6/10/2017 1:44:00 PM Fountain By 751	7/6/2017 8:36:00 AM	Lead (1st Draw)	2.32 ug/l	15 ug/L	Std Method 3113B
0617-6310-41	6/10/2017 1:47:00 PM Fountain By 757	7/6/2017 8:36:00 AM	Lead (1st Draw)	4.06 ug/l	15 ug/L	Std Method 3113B
0617-6310-42	6/10/2017 1:49:00 PM Teachers Lounge 761 Sink	7/6/2017 8:36:00 AM	Lead (1st Draw)	2.64 ug/l	15 ug/L	Std Method 3113B
0617-6310-5	6/10/2017 1:51:00 PM Fountain By 851	7/6/2017 8:36:00 AM	Lead (1st Draw)	2.99 ug/l	15 ug/L	Std Method 3113B
0617-6310-6	6/10/2017 1:54:00 PM Fountain By 857	7/6/2017 8:36:00 AM	Lead (1st Draw)	4.96 ug/l	15 ug/L	Std Method 3113B
0617-6310-7	6/10/2017 1:56:00 PM Teachers Rm 861 Sink	7/6/2017 8:36:00 AM	Lead (1st Draw)	2.75 ug/l	15 ug/L	Std Method 3113B
0617-6310-8	6/10/2017 2:05:00 PM Fountain FF By Rm 5143 Source	7/6/2017 8:36:00 AM	Lead (Source)	< 2.00 ug/l	5 ug/L	Std Method 3113B
0617-6310-9	6/10/2017 2:10:00 PM Ice Machine Kitchen	7/6/2017 8:36:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, July 11, 2017

NJDEP Laboratory Certification # 14006

Page 3 of 4



RAdata, Inc.
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: Gary Tattersall
Ocean Township School District
163 Monmouth Road
Oakhurst, NJ 077550000

Laboratory Results

Sample Number	Sample Location	Collected By
0617-6310	1200 West Park Avenue - Ocean Twp	Richard, Hand

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
------------	-----------	----------	-----------	--------	-------	--------

**Some or All of the parameters tested on this report
DID NOT PASS NJ Drinking Water Standards.**

This report represents results associated to the point of collection location in the structure only. It is recommended that other locations within the structure where water can be consumed, be tested to verify compliance to state and federal drinking water regulations.

Reviewed and Approved by:

Timothy P. Kroder, Laboratory Manager

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, July 11, 2017

NJDEP Laboratory Certification # 14006

Page 4 of 4